

Suggested Temperature Set Points

Set Points

| | |
|-------------------------------|--|
| Classrooms and Offices | 68 F |
| Hallways | 65 F |
| Gymnasiums | 65 F |
| Auditoriums | 68 F |
| Cafeterias | 68 F |
| Vestibules/Enclosed Entrances | 55-60 F (many not heated unless there is a freeze problem) |
| Daycares | 70-72 F |
| Storage/Unoccupied Areas | 50-55 F |
| Air Conditioning | 76 F |
| Night Setback | 55-60 F Heat- dependant on warm-up ability |
| | 80 F Air Conditioning |